



TRIANGLE FIRE

FIRE SAFETY & SECURITY ENGINEERES

Address: - S. No. 13/2/15, Shitole Nagar, Spicer College Rd,
47/1/244/2, Old Sangavi, Pune, Maharashtra 411027

Email: trianglefire4@gmail.com Website: www.trianglefires.com

SANJAY DESHMUKH

+919669506670

RAJU SARODE

+919890059950

Ref. No. TF2023-24/B-012

Date – 04/07/2023

FORM B

[See section 3 (3) and rules 4 (2)]

Six monthly certificates to be given by Maharashtra Fire service Licensed Agency in every January and July to the owner or the Occupier for compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I/We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely.

M/s. THE KALYANI SCHOOL,

Address: - S. NO. 12 MANJARI (BUDRUK), PUNE- 412307.

I/We further certify that these installations in the above mentioned buildings are maintained in good repair and efficient conditions during the period from,

01-01-2023 to 30-06-2023

As required under the provisions of the **Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007)** the details of the work and related activities which I or we have executed or performed are mentioned in the list.

Place: **PUNE**

Date: **04/07/2023**

License Number: **MFS/LA/F-398/D-391**

License issued on: **23/07/2022**



**SANJAY
DESHMUKH**

Seal & Signature of Licensed Agency.

Digitally signed by
SANJAY DESHMUKH
Date: 2023.07.10
11:09:27 +05'30'



TRIANGLE FIRE

FIRE SAFETY & SECURITY ENGINEERES

Address: - S. No. 13/2/15, Shitole Nagar, Spicer College Rd,
47/1/244/2, Old Sangavi, Pune, Maharashtra 411027

Email: trianglefire4@gmail.com Website: www.trianglefires.com

SANJAY DESHMUKH

+919669506670

RAJU SARODE

+919890059950

Ref. No. TF2023-24/B-012

Date – 04/07/2023


Equipment's Installed Report

M/s. THE KALYANI SCHOOL,

Address: - S. NO. 12 MANJARI (BUDRUK), PUNE- 412307.

Details of Work

Sr. No	DESCRIPTION OF EQUIPMENT'S	QUANTITY
A)	FIRE HYDRANT SYSTEM	
1)	Fire hydrant Point	28 NOS
2)	Fire Hose Box	28 NOS
3)	RRL Hose Pipe 15Mtr. With SS Male/ Female Coupling GI Binding	56 NOS
4)	Branch Pipe/ Nozzle	28 NOS
5)	First Ad Hose reel Drum with Rubber Hose Pipe	12 NOS
6)	Fire Sprinkler	104 NOS
B)	FIRE ALARM SYSTEM	
1)	Control Panel for Fire alarm System 6Loop	03 NOS
2)	Smoke Detector	330 NOS
3)	Manual Call Point	27 NOS
4)	Hooters	27 NOS
5)	Beam Detector	03 NOS
C)	FIRE PUMP ROOM	





TRIANGLE FIRE

FIRE SAFETY & SECURITY ENGINEERES

Address: - S. No. 13/2/15, Shitole Nagar, Spicer College Rd,
47/1/244/2, Old Sangavi, Pune, Maharashtra 411027

Email: trianglefire4@gmail.com Website: www.trianglefires.com

SANJAY DESHMUKH

+919669506670

RAJU SARODE

+919890059950

Ref. No. TF2023-24/B-012

Date – 04/07/2023

1)	Jockey Pump 10 HP	01 NOS
2)	Main Pump 40 HP	01 NOS
3)	Sprinkler Pump 40HP	01 NOS
4)	D.E. pump / D. G. Back-up 52HP	01 NOS
5)	Water Tank 50,000 Ltr.	01 NOS
6)	Booster Pump 5 HP	02 NOS
D)	FIRE EXTINGUISHER	
1)	DCP Type Fire Extinguishers Capacity 4, 6, 9 kg.	43 NOS
2)	CO2 Type Fire Extinguishers Capacity 4.5 Kg	36 NOS
3)	FOAM Type Fire Extinguishers capacity 09 Ltr.	02 NOS

Note: : We have Checked Tested the system but it is the Duty of owner of the building to keep the entire systems operational every time by keeping water in fire water tank and all pumps in pressurized mode.

Place: **PUNE**

Date: **04/07/2023**



**SANJAY
DESHMUKH**

Digitally signed by
SANJAY DESHMUKH

Date: 2023.07.10
11:16:05 +05'30'

License Number: **MFS/LA/F-398/D-391**

License issued on: **23/07/2022**

Seal & Signature of Licensed Agency.



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / F-398 / D- 391

Date: 23.07.2022

License is hereby granted under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Triangle Fire** having their registered office at **S.No. 13/2/15, Shitole Nagar, Spicer College Rd, Old Sanghavi, Pune 411027** and their contact details are Office Number: 9669506670 and Email ID: trianglefire4@gmail.com with PAN registration No. AAQFT1516J and GST No. 27AAQFT1516J1ZV to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- 1. Fire Fighting and Sprinkler System:** **Class D**
- 2. Detection and Fire Suppression System:** **Class D**

M/s. Triangle Fire shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **23.07.2022 to 22.07.2023**

Hatyal
Kiran
Digitally signed
by Hatyal Kiran
Date: 2022.07.30
15:49:10 +05'30'

Asst Director

**SANJAY
DESHMUKH**

Digitally signed by
SANJAY DESHMUKH
Date: 2022.07.30
14:47:25 +05'30'

SANTOSH
SHRIDHAR
WARICK

Digitally signed by
SANTOSH SHRIDHAR
WARICK
Date: 2022.07.30 18:20:25
+05'30'

(S S Warick)
Director

Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

for The Kalzani School only
* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.

date - 04/07/2023



Form B-012